



ADDENDUM #3

RFP 25-007

**Electric Circuit Installation**

This addendum is being issued to address questions submitted on RFP 25-007:

1. In regards to installation of the underground circuit, what materials is the city providing? What materials is the contractor responsible for? Is the power company providing the transformer? What is UM2-5A – 200 AMP 65 KS Fuses listed on sheet 1 on Ridgeway Rd?

The city is providing all materials and transformer; That's the fuses for the 1500 kva 3 phase padmount transformer.

This addendum should be signed and returned with your proposal. Failure to do so may result in the proposal being non-responsive.

Christy Case  
Finance Director  
City of Commerce

Company Name \_\_\_\_\_  
Authorized Representative \_\_\_\_\_