



ADDENDUM #1

RFP 25-008

2025 LMIG Street Paving

This addendum is being issued to address questions submitted on RFP 25-008:

1. What kind of Asphalt Material do you want the Contractor to use for the 1.5 inch Topping? 9.5 mm Type I? 9.5mm Type II? 12.5mm? **The material being used is 9.5 mm Type II.**
2. Will the Asphalt Material need to meet current GDOT Specifications? **Yes, it will need to meet GDOT specs.**
3. Will you allow Recycled Asphalt to be used in the new Asphalt Materials in accordance with GDOT Specifications? Or do you want to use Virgin Asphalt Materials? **Virgin Asphalt is preferred**
4. Will there be a pre-bid meeting for this project? **No.**

This addendum should be signed and returned with your proposal. Failure to do so may result in the proposal being non-responsive.

Christy Case
Finance Director
City of Commerce

Company Name _____
Authorized Representative _____