



ADDENDUM #5
RFQ 24-001

Bowden Street Tank Painting and Inspection

This addendum is being issued to address questions submitted on RFQ 24-001

Q1. What is the distance from the leg to the fence line?

A1. Approximately 50' (fifty feet)

Q2. Is there a name plate with the data?

A2. Erected in Newnan, GA in 1952 by RD Pole Manufacturing; capacity (40,000?) Height to Bowl 70' (seventy feet)



This addendum should be signed and returned with your proposal. Failure to do so may result in the proposal being non-responsive.

Christy Case
Finance Director
City of Commerce

Company Name _____

Authorized Representative _____