



ADDENDUM #3

RFP 26-016

SIDEWALK RESTORATION AND CONSTRUCTION 2026

This addendum is being issued to address questions for RFP 26-016:

1. Is subbase required?

Subbase is not required for this project however, 98% compaction of the soil underneath the concrete is required.

This addendum should be signed and returned with your proposal. Failure to do so may result in the proposal being non-responsive.

Debby Saxon
Finance Specialist
City of Commerce

Company Name _____

Authorized Representative _____